

**TOWN OF CUMBERLAND, RI
SEWER DEPARTMENT
ABBOTT STREET PUMP STATION
BID NO. 2023-1212-01
Addendum #1**

Notice to All Prospective Bidders

Addendum #1 RELEASED (December 7, 2023)
--

The following changes are made to the bid documents for BID NO. 2023-1212-01:

Plans

Sheet E-2: One Line Diagram – Revise “Sewage Pump #1 208V 3-Phase” to “Sewage Pump #1 230V 3-Phase” and change “7.5” (motor horsepower) to “4”.

Sheet E-2: One Line Diagram – Revise “Sewage Pump #2 208V 3-Phase” to “Sewage Pump #2 230V 3-Phase” and change “7.5” (motor horsepower) to “4”.

Sheet E-4: Wet Well Plan – Revise “7.5 to “4” for Sewage Pump #1 and Sewage Pump #2

Specifications

Specification Section 11310, 1.03.E.1. – Revise “Each pump shall be equipped with a 4 HP submersible electric motor, capable to operate on a 460 volt, 3 phases, 60 hertz voltage supply.” to “Each pump shall be equipped with a 4 HP submersible electric motor, capable to operate on a 230 volt, 3 phases, 60 hertz voltage supply.”

Bidders are reminded that they must acknowledge receipt of any and all Addendums on page 00300-3 of the Bid form.

The Town reserves the right to reject any and all bids as determined to be in the best interest of the Town and to waive minor informalities.