



**TOWN OF
NORTH KINGSTOWN, RHODE ISLAND**

**100 FAIRWAY DRIVE
NORTH KINGSTOWN, R.I. 02852-5762
PHONE: (401) 294-3331
FAX: (401) 583-4140**

REQUEST FOR PROPOSALS

**DEPARTMENT OF PUBLIC WORKS
NORTH KINGSTOWN FIRE DEPARTMENT
STATION # 5 GENERATOR & ATS REPLACEMENT**

ADDENDUM #1

Please note the following:

- See attached Attendance Sheet from Pre-Bid Conference
- The Contractor's Lump Sum Base Bid submission will include the removal and disposal of all existing generator equipment and operational components that are to be abandoned with the replacement and installation of the new generator, including all fuel-oil.
- For the purposes of generator power cut over, the Contractor will be allowed one working day (7 AM to 7 PM) for a building power outage. The Contractor will provide the Fire Department with a notice two days prior to loss of power. For all additional time needed for power outages, the Contractor will provide temporary power for the building and include that cost in their Base Bid.
- Construction operations and activities, excluding the electrical interruption previously mentioned, must not interfere with the operations of the Fire Station. These include building security, accessibility in and out of the Fire Station, protection of Station equipment and general facility operations.

IT IS THE RESPONSIBILITY OF THE PROSPECTIVE BIDDERS TO MONITOR THE TOWN AND/OR STATE OF RHODE ISLAND PURCHASING WEBSITES FOR ANY SUBSEQUENT BID ADDENDUM. NO ADDENDA WILL BE ISSUED OR POSTED WITHIN FORTY-EIGHT (48) HOURS OF THE BID SUBMISSION DEADLINE.