



DATE: 5/23/23

Addendum # 2

BID NO.: 101270
OPENING: 6/1/23 @ 12:00 PM
COMMODITY: TOOTELL DIVING WELL RESURFACING

This addendum is being issued to provide the following:

- Document 00900 – Addenda and Modifications – Addendum No. 2

Purchasing Department
The University of Rhode Island

Rev. 9-1-15

DOCUMENT 00900 – ADDENDA AND MODIFICATIONS

ADDENDUM NO. 2 – 5/23/2023

From:	Tecton Architects, PC	<i>Home Office:</i>	<i>Branch Office</i>
		<i>34 Sequassen Street</i>	<i>17 Railroad Avenue</i>
		<i>Hartford, CT 06106</i>	<i>Westerly, RI 02891</i>
		<i>Tel. 860-5480802</i>	<i>Tel. 401-5967555</i>

To: Prospective Bidders

This Addendum forms part of the Contract Documents and modifies the Bidding Documents dated 4/11/2023 with amendments and additions noted below.

Acknowledge receipt of this Addendum in the space provided in the Bid Form. Failure to do so may disqualify the Bidder.

This Addendum consists of 1 Page.

CHANGES TO DRAWINGS

1. DRAWING #DP-1

Revise first sentence of demolition key-note 5, as follows:

“Use Hydro-Blasting to remove any loose plaster finishes down to sound plaster or original sound concrete/shotcrete. Collect water and plaster residue by vacuuming into a tank truck. If plaster is still loose, chip out any loose plaster. Any cracks ...”

CHANGES TO PROJECT MANUAL

None.

END OF ADDENDUM #2