



Date: 6/6/23

## **Addendum # 1**

BID NO.: 101278  
OPENING: 6/13/23 @ 1:00 pm  
COMMODITY: Fire Suppression System Testing & Inspection

This addendum was generated to answer the following questions submitted for BID 101278 by the question period deadline of 6/2/23 at 12:00 pm. No other questions pertaining to this bid will be accepted or answered moving forward.

Q1: Are you asking for the cleaning hoods to be included?

A1: No.

Q2: Can you confirm that any replacement parts (links, batteries, nozzles, bulbs etc.) and repair services are to be invoiced separately and are not part of the testing cost? If they are included, can you please provide how many links, nozzles, bulbs etc. are installed in each system?

A2: Replacement parts and repair services are to be invoiced separately and are not part of the testing cost.

3: Attachment B, Page 1 states inspections to include the fire extinguisher unit. Can you please confirm that these would be the extinguishers in the kitchen area only?

A3: These are fire suppression tanks, not fire extinguishers. They are part of the hood fire suppression systems.

Q4: How many extinguishers are in the kitchen areas?

A4: Again, they are not portable extinguishers - these are fire suppression tanks, not fire extinguishers. They are part of the hood fire suppression systems.

Q5: Is all testing performed during normal business hours?

A5: Yes, the majority of testing is scheduled during normal working hours, usually from 8:30 to 4:00. There may be a few early scheduled tests for particular departments. Also, please note that URI will provide a fire alarm technician for escort and/or for fire alarm shut down, if necessary.

Kristen Bellotti, Asst University Purchasing Agent  
Purchasing Department  
The University of Rhode Island

Rev. 9-1-15