



DATE: December 5th, 2024

Addendum# 1

BID NO.: 101440
OPENING: 12/20/24 at 1:00 PM
COMMODITY: PARKING TECHNOLOGY IMPROVEMENTS

This amendment is being issued to:

1. Provide clarifications to the bid specifications.
2. Provide a copy of the Non-Mandatory Pre-Bid Sign-In Sheet

Purchasing Department
The University of Rhode Island

Rev. 9-1-15



BID 101440 Clarifications:

1. Clarify Attachment B (Provided by URI), who is *installing* items provided? Will it be under this contract or others at a later date. (also refer to 11 1200-1 Part 1, Section 1.2 Summary, Item 1). Also 11 1200-10 Part 2 Products, 2.1, A, says the contractor shall *provide* the following cameras, equipment, mounts, accessories, licenses, etc.

Answer: All items within Attachment A and B are to be provided and installed by the Owner. The Contractor shall support the Owner during the installation process of the Camera but is not anticipated to make the physical connections.

11 1200-1 Part 1, Section 1.2, Item 1 correctly states that “the Motorola Vigilant LPR system shall be provided by the owner (URI).”

11 1200-10 Part 2 Products, 2.1, A shall be revised to state “~~Division 27 contractor~~ **Owner** shall provide the following cameras, equipment, mounts, accessories, licenses, etc., for a complete, fully functional, and integrated LPR parking enforcement system at each location listed.”

2. Clarify Page E2.0 where concrete ductbank is required, appears some conflict. Also provide Ductbank Schedule per General Notes #1 in Detail 1.

Answer: Duct banks shall be provided as specified in the Contract Documents. Conduits and duct banks are noted on plans. A schedule is not provided.

3. Will the Wayfinding Sign have its own specification section? Also, if Wayfinding sign is provided, how does it work if the remainder of the items on Attachment B are not provided?

Answer: Manufacturer information for the signs is provided in Spec Section 11 1200, and details on sizing and mounting are provided on Page C3.3 and E2.0. All items on Attachment B will be provided by the Owner.

4. Were permit fees provided as part of the Project Approval Letter

Answer: Permitting fees are not provided as part of the Project Approval Letter. The Contractor shall cover all permitting fees.

5. Will traffic be shut down at North Entrance during construction, work will not be able to be performed with traffic.



Answer: Access to all parking lots must be maintained throughout construction. Temporary closures may be made when school is not in session. Any closures must be coordinated with Owner in advance. The Contractor is responsible for all traffic control means and methods.

6. Page C2.1 notes#6 refers to requiring a surveyor for layout of a building, There is no building proposed within this project. Will a surveyor still be required?

Answer: A surveyor is not required for layout.

7. The trees along Flagg Road may have an impact to the root system from trench excavation and may cause the trees to be compromised.

Answer: The Contractor shall work with the University and its Lands & Grounds group to assess protective measures for root systems prior to excavation. Minor pruning of large roots may be required immediately under the tree canopies, and should be included in the base bid.

8. Is a police detail required for the road crossing or can a flagger be used? Do campus police do details or would it be a town if required?

Answer: Police details, if required, shall be provided by the Contractor.

9. Can you clarify the Camera Pedestal and Pole Base details on Page 2.1 and C3.3 with differing details. We typically use precast. The plans call for cylinder liners and casings which is not a typical installation method for these given the shallow depth.

Answer: The “LPR Pole Detail with Extended Footing” shall be used for pole installations. As stated in the detail, cylinder liners or casings may be used to prevent collapse of excavation if necessary.



NON - MANDATORY PRE-BID CONFERENCE SIGN-IN SHEET

11:23 am

BID NUMBER:	101440	PURCHASING REPRESENTATIVE:	Andrea Boucher
BID TITLE:	Parking Technology Improvements		
LOCATION:	210 Flagg Road, 2nd Floor, Room 207, Kingston, RI 02881		
PRE BID DATE AND TIME:	12/2/24 at 11:00 AM		

Company Name:	Representative:	Email Address:	Phone Number
URI - Purchasing	Andrea Boucher	andrea.boucher@uri.edu	401-874-9133
William Anthony	JIM MARSH Tony RASO	jim@waexcavating.com	401-294-2320
URI-OCP	Matthew Fuller	Matthew-Fuller@uri.edu	(860) 884-3227
URI OCP	Ken Burke	Ken_Burke@URI.GOV	401 474 4700
URI OCP	Dennis Blaudette	Dennis.Blaudette@URI.edu	401-641-5478
RICON	Daniel ZUMMO	DZUMMO@RICONVIA.COM	603-831-860-8566
PARB	MATT ALFORD	MALFORD@PARBCORP.COM	401.374.4100